MATCH LINE N.4785 FOR CONTINUATION SEE DWG. E-J-K

TOWER A ELEV. 310' N.I.C. EXCEPT AS SHOWN

TOWER 'B' ELEV. 310' N.I.C. EXCEPT AS SHOWN

FOR CONTINUATION SEE RISER ON DWG E-J-K-16

RAMP 'B' SEE NOTE #5

STAIR 'A'

2-5" CONDUIT SLEEVES (SEE NOTE #7).

UH-SL-810 3Ø, 460V 9W

MOTORIZED DOOR 460V-3Ø (SEE NOTE #9)

FOR CONTINUATION OF RAMP LTG. SEE DWG E-K-13

RAMP 'M' SEE NOTE #6

SOUTH PROJECTION ELEV. 305

WEST STREET

FOR CONTINUATION REFER TO DWG E-K-15

KEY OPERATED REMOTE START-STOP PUSH BUTTON FOR EXH. FAN E-32-S6 REFER TO DWG. E-J-K-17 FOR WIRING DIAGRAM

STAIR K-17

IN VESTIBULE

ROAD PHONE

BALL ROOM (N.I.C.)

HOTEL ESC. H1 & H-4 (N.I.C.)

HOTEL LOBBY (N.I.C.)

HOTEL PASSENGER ELEVS (N.I.C.)

HOTEL SERVICES (N.I.C.)

PASS. ELEV. LOBBY

MOUNT OVER DOOR

MOUNT 9'-0" ABOVE EL. 324'-6" (OVER SHEAVE LEVEL)

ELEV. LOBBY

STAIR K-2 (N.I.C.) DOWN TO TYPE FC FIXT. IN ELEV. LOBBY ON EL. 294

STAIR K-3

HOTEL ESC. (N.I.C.) H-3 & H-4

HOTEL SERVICE ELEVS (N.I.C.)

CORRIDOR (N.I.C.)

SHOP (N.I.C.)

M.E.R. #2 (N.I.C.)

FAI PLENUM

STAIR K-6A

PIPE SPACE

STAIR K-6

STAIR K-5

STAIR K-4 (N.I.C.)

STAIR K-1 (N.I.C.) IN STAIRWELL

STAIR K-2

ELEVATOR MACHINE ROOM

AUXILIARY SERVICES

A.C. EXHAUST SHAFT

STAIR K-7A PIT TYPE 'PE'

RAMP 'N' SEE NOTE #6

LIBERTY STREET

NORTH

KEY PLAN

NOTES:

1. LIGHTING FIXTURES IN RAMP 'M' TO BE PENDANT MOUNTED FROM 552' LEVEL MTG. HT. TOP OF FIXTURE 9'-1" A.F.F. FIXTURES SHALL BE TYPE "F1", UNLESS SPECIFICALLY NOTED OTHERWISE.
2. FOR EMERGENCY STAIR AND EXIT LIGHT RISER DIAGRAM. SEE DWG. E-J-K-20.
3. FOR LIGHT AND POWER RISER DIAGRAM SEE DWG. E-J-K-18
4. MAGNETIC STARTER & PUSH BUTTON (OPEN-CLOSE-STOP) SHALL BE FURNISHED BY DOOR MANUFACTURER, ELECTRICAL CONTRACTOR SHALL INSTALL AND CONNECT.
5. FOR RAMP 'A' LIGHTING AND SNOW MELTING SYSTEM SEE DWG. E-J-K-17.
6. FOR RAMP 'M' LIGHTING AND SNOW MELTING SYSTEM SEE DWG. E-J-K-16.
7. FOR DETAIL OF CONDUIT SLEEVES SEE DWG. E-J-K-22.
8. REFER TO SPECIFICATIONS FOR IDENTIFICATION AND MARKINGS OF ELECTRICAL EQUIPMENT AND FEEDER CONDUITS ORIGINATING EITHER FROM TRADE CENTER AND/OR PATH DISTRIBUTION FACILITIES, AND WHICH EXTEND INTO ADJACENT AREAS.
9. FOR ALL MOTOR CONTROL SCHEMATICS REFER TO DWG. E-J-K-27.
10. FOR EMERGENCY SINGLE LINE DIAGRAM SEE DWG. E-K-10A.
11. FOR EMERGENCY CONTROL SYSTEM RISER DIAGRAM SEE DWG. E-K-11A.

RECEIVED
JUL 31 1990
LESLIE E. ROBERTSON ASSOCIATES
811 EAST 46TH ST., N.Y.C. 10017

BULLETINS NOT DATED ARE IN PROCESS OF COMPLETION.

CONTRACT DRAWING date SEPT. 3, 1968

NO.	DATE	BUL. NO.	BY
15	6-73	56-213	
14	6-22-73	56-210	
13	6-6-73	56-209	

REVISIONS

NO.	DATE	BUL. NO.	BY
12	3-3-71	56-169	
11	11-20-70	56-126	
10	9-28-70	56-119	
9	4-7-70	56-90	
8	2-2-70	56-84	
7	8-2-69	56-24	
6	2-13-69	56-18	
5	2-14-68	56-12	
4	8-8-68		
3	7-31-68		

REVISIONS

APPROVED

CHIEF, PLANNING DIVISION

DATE

THE WORLD TRADE CENTER
THE PORT OF NEW YORK AUTHORITY

MINORU YAMASAKI & ASSOCIATES
MINORU YAMASAKI, ARCHITECT

EMERY ROTH & SONS
RICHARD ROTH, ARCHITECT

WORTHINGTON, SKILLING, HELLE & JACKSON
STRUCTURAL ENGINEERS

JAROS, BAUM & BOLLES
MECHANICAL ENGINEERS

JOSEPH R. LORING & ASSOCIATES
ELECTRICAL ENGINEERS

THE PORT OF NEW YORK AUTHORITY
PAVING, UTILITIES, FOUNDATIONS

TITLE
LIGHTING AND POWER SUB-GRADE PLAN-ZONE 'K' ELEV. 310

DRAWN	R.F.H.	CHECKED	J.R.L.
SCALE	1/16"=1'-0"	DATE	JUNE 25, 1968
PROJECT NUMBER	402.00	SHEET 15 OF 51	
DRAWING NUMBER	E-K-15		

1/16"=1'-0" scale