




℄ & DIMENSIONS IN HC4 ARE RELATED TO HOLES PUT IN BEARING END OF FLOOR TRUSSES WHICH ARE SIMILAR WITH BUT NOT EXACTLY ALIGNED WITH HOLE ℄ ON THE COLUMN CLIPS & BRACES.


PANEL NO. A1A SIZE 20'-0 x 59'-9".






















NOTE ALL ARC WELDS TO BE MADE WITH LOW HYDROGEN RODS IN THE E-70 SERIES OR EQUAL. UNLESS SHOWN OTHERWISE ALL CONNECTION ARC WELDS SHALL BE 1/4" X 1" FULL THROAT FILLET.

FIELD PUNCH COVER PLATES OVER END STIFFENERS WT.C. 223.00





CLIP ANGLE LOCATION FOR DIAGONAL FLATS 4½" ABOVE COLUMN CLIPS FOR TRUSS BEARING

REQUIRED MATERIAL PER PANEL				
MATERIAL	MK	PCS	SIZE	REF. DRWG.
FLOOR TRUSSES	T1A	6	C32T1A - 59'-9"	ST201A
ON JOINT TRUSSES	T11	4	24T11 - 10'-11"	ST211
	A1	5	3"x2½"x¼"x 9'-11"	ST 403
ANGLE	A2	4	3"x2½"x¼"x 5'-11⅞"	ST 403
	A3	2	3"x2½"x¼"x 5'-11¾"	ST 403
FLOOR FLATS	F1	6	1½"x ⅜"x 6'-8"	ST 402
PATCH PLATES	PP1	24	2"x ¼"x 0'-9"	ST 400
	PP2	24	3"x ⅜"x 0'-9"	ST 400
COVER PLATES	A	2	9"x.035"x13'-11½"	ST303
	B	6	9"x.035"x 15'-2"	ST303
	C	5	9"x.035"x13'-2½"	ST303
	D	4	9"x.035"x 2'-1"	ST303
	C1	24	2"x1½"x¼"x 0'-6"	ST400
STUD SHEAR ANCHOR	SA2	16	⅞" ø REBAR x 0'-9"	ST 400
DAMPING SADDLE	DUS-1	2	3½"x3½"x ⅜"x3'-0⅞"	ST298
	DUS-2	2	3½"x3½"x ⅜"x3'-6⅞"	ST298
CONNECTION BAR	CB1	2	[illegible]	ST 400
CONNECTION PLATES	P1	16	3½" x ⅜"x 8'½"	ST 400
	P2	8	4½" x .39" x 0'-9"	ST 400
	P3	8	4½" x .39" x 1'-0"	ST 400

LETTERS AND NUMBERS IN ELLIPSES (1C) INDICATE CONNECTION DETAILS SHOWN ON SHEETS CD 201 OR CD 202.

NO.	DATE	REVISION	BY
3	3-11-69	AS NOTED	GCC
2	2-17-69	AS NOTED	C.F.C.
1	7-12-63	GENERAL	T.M.C.

AB4,3,31&39	1-3-68
AB4-5&16	1-3-68
AB4 41	1-3-68
SA [illegible]	10-20-67
AB3 [illegible]	1-3-68
AB1-2	2-15-68
AB2-6	2-15-68

[illegible]
A. E. [illegible] TENANT TERMINAL N.Y.C.
[illegible]
THE PORT OF NEW YORK AUTHORITY

BLDG. A FLOORS 12-24, 26-38 (NORTH & SOUTH); 49-58, 60-66, 68,
69 (NORTH) PANEL A1A - 20'-0" x 59'-9"

FABRICATED BY LACLEDE STEEL COMPANY
ARNOLD, MISSOURI & ALTON, ILLINOIS
APPROVED FOR FABRICATION BY DV [illegible] FOR BONYA
APPROVED FOR FABRICATION BY [illegible] FOR FABRICATOR
DETAILED BY A.C. WELDS
DATE 3/24/69
DETAIL DRAWING NO. 7-A&3-3 4-1-68 PLATE
DRAWN BY [illegible]
DATE FEB 24, 1969
CHECKED BY J.A. PAUL
DATE FEB 24, 1969
IN CHARGE OF FABR. DEV.
FABRICATION CONT. NO. W.T.C. 221
SHEET NO. FD A1A