WORLD TRADE CENTER
FLOOR GRID TRUSSES
DESIGN DATA

TRUSS UNIT MARKED 2C32T5 Refer to drawings ST 101, 6, 8 .

Clearspan "L" = 34.83 ft. Spacing = 6.67 ft.

Applicable Total Moment = 1,920,000 inch pounds. [31' Partial Loading]

Based on 154 lbs./sq. ft. Total Load "w".

Applicable End Reaction = 18,000 pounds.

Based on 154 lbs./sq. ft. Total Load "w".

Applicable Total Constr. Moment = 585,000 inch pounds.

Based on 46 lbs./sq. ft. Construction Load.

Applicable Constr. End Reaction = 5470 pounds.

Based on 46 lbs./sq. ft. Construction Load.

"V" Shear at End Panel = 14,920 pounds. ED = 3.0 ft.

WEB MEMBER #1 Distance from End Panel = 0.0 ft.

Applicable Shear $V_x$ = 14,920 lbs. $f_y$ = 50,000 psi

Slope = 2.65 $f_s$ = 30,000 psi

$\ell$ = — in. $f_{sc}$ = — psi

Reqd. Area = 1.32 sq. in. Use 2-0.92"DIA Area = 1.33 sq. in.

WEB MEMBER #2 Distance from End Panel = 0.0 ft.

Applicable Shear $V_x$ = 14,920 lbs. $f_y$ = 36,000 psi

Slope = 1.00 $f_s$ = — psi

$\ell$ = 216.0 in. $f_{sc}$ = 11,200 psi

Reqd. Area = 1.33 sq. in. Use 2-0.92"DIA Area = 1.33 sq. in.

WEB MEMBER #3 Distance from End Panel = 4.87 ft.

Applicable Shear $V_x$ = 9,920 lbs. $f_y$ = 36,000 psi

Slope = 1.162 $f_s$ = — psi

$\ell$ = 30.0 in. $f_{sc}$ = 8,750 psi

Reqd. Area = 1.32 sq. in. Use 2-0.92"DIA Area = 1.33 sq. in.