SKILLING, HELLE, CHRISTIANSEN, ROBERTSON — Structural & Civil Engineers


PROJECT: THE WORLD TRADE CENTER


TITLE: ~~HEAT EXCHANGER & PUMP BASE~~ - TOWER A FLOOR 43

DATE: 12/14/71


REVISIONS

2/18/72





Part Plan - Floor 43



See approved Mech. Shop Dwgs. for locations of 6" thick pump bases. Reinforce with #4@8 T.&b. each way.

Part Plan - Floor 43

Notes:

1. All work and materials shall conform to project specifications.
2. All concrete shall be stone aggregate concrete f'_c = 3000 psi.
3. All dimensions and locations shall be verified with, and all embeded items shall be coordinated with, approved Mechanical shop Drawings before casting concrete bases.

LICENSED PROFESSIONAL ENGINEER — LESLIE E. ROBERTSON — No. 34980 — UNIVERSITY OF THE STATE OF NEW YORK

DESIGNED

DRAWN J. Adams

CHECKED W. Fellows

19-A-1105.1